



NOTES:

1. LIGHT GAUGE STEEL FRAME SHALL BE DESIGNED FOR SPECIFIC PROJECT LOADS AND CONDITIONS TO MEET LOCAL BUILDING CODES BY LICENSED ENGINEER.
2. REFER TO APPLICATION INSTRUCTIONS FOR THE APPROVED TREMCO CPG AIR BARRIER SYSTEM SELECTED FOR AWRB AND FLASHING APPLICATION.
3. OFFSET SUBSTRATE JOINTS FROM INSULATION BOARD JOINTS BY 8" (203 MM) MINIMUM, HORIZONTALLY AND VERTICALLY.
4. FOR THE BASE COAT AND MESH APPLICATION FOLLOWING THIS STEP SEE OSL - 01 & 02.

This detail is for general informational purposes only. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project with respect to any architecture, engineering, and design requirements, including any local building code requirements. If this document is not reviewed and the product is not approved for use by a licensed design professional, the customer agrees that the detail may contain substantive flaws requiring correction, and hereby releases Tremco CPG Inc. from any and all liability related to the design and installation of the product. This detail is subject to change without notice. Contact Tremco to ensure you have the most recent version.

**Outsulite™ Panel System**

 <p>Dryvit Technical Support: 800-556-7752</p>	Detail: EPS Board Installation			File Name:	 <p>OSL 5</p> <p>Construction Products Group</p>
	Drawn by: EM	Checked by: CW	Scale: NTS		
	Revision #: 0	Revised by: NA	Date: 6/27/2024		
<p><a href="http://www.tremcocpg.com">www.tremcocpg.com</a></p>					