

- DRYVIT RECOMMENDS THAT GROUND 3.
 FLOOR APPLICATIONS AND ALL
 FACADES EXPOSED TO ABNORMAL
 STRESS, HIGH TRAFFIC, OR
 DELIBERATE IMPACT HAVE THE BASE
 COAT REINFORCED WITH PANZER®
 MESH PRIOR TO STANDARD OR
 STANDARD PLUS MESH. LOCATION OF
 HIGH IMPACT ZONES SHOULD BE
 INDICATED ON CONTRACT
 5.
 DRAWINGS.
- 2. LIGHT GAUGE STEEL FRAME SHALL BE DESIGNED FOR SPECIFIC PROJECT LOADS AND CONDITIONS TO MEET LOCAL BUILDING CODES BY LICENSED ENGINEER.
- REFER TO APPLICATION INSTRUCTIONS FOR THE APPROVED TREMCO CPG AIR BARRIER SYSTEM SELECTED FOR AWRB AND FLASHING APPLICATION.
- PANEL JOINT LOCATIONS AS PER APPROVED SHOP DRAWINGS.
- INSULATION BOARD TO BE MINIMUM 3/4" (19 MM).
- REFER TO DETAIL OSL 06MD FOR VERTICAL SEAL OF DRYVIT PANEL WEEP SYSTEM.

This detail is for general informational purposes, only. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project with respect to any architecture, engineering, and design requirements. Including any local building code requirements. If this document is not reviewed and the product is not approved for use by a licensed design professional, the customer agrees that the detail may contain substantive flaws requiring correction, and hereby releases Tremco CPG Inc. from any and all liability related to the design and installation of the product. This detail is subject to change without notice. Contact Tremco to ensure you have the most recent version.

Outsulite™ Panel System



Detail: Horizontal Panel Connection - Drainage Option		
Drawn by:EM	Checked by: CW	Scale: NTS
Revision #: 0	Revised by: NA	Date: 6/27/2024

