

## NOTES:

- DRYVIT RECOMMENDS THAT GROUND 3. FLOOR APPLICATIONS AND ALL FACADES EXPOSED TO ABNORMAL STRESS, HIGH TRAFFIC, OR DELIBERATE IMPACT HAVE THE BASE COAT REINFORCED WITH PANZER® MESH PRIOR TO STANDARD OR 4. STANDARD PLUS MESH. LOCATION OF HIGH IMPACT ZONES SHOULD BE INDICATED ON CONTRACT 5. DRAWINGS.
- LIGHT GAUGE STEEL FRAME SHALL BE DESIGNED FOR SPECIFIC PROJECT LOADS AND CONDITIONS TO MEET LOCAL BUILDING CODES BY LICENSED ENGINEER.
- REFER TO APPLICATION
  INSTRUCTIONS FOR THE APPROVED
  TREMCO CPG AIR BARRIER SYSTEM
  SELECTED FOR AWRB AND FLASHING
  APPLICATION.
- PANEL JOINT LOCATIONS AS PER APPROVED SHOP DRAWINGS.
- EPS TO BE MINIMUM 3/4" (19 MM). MAINTAIN 3/4" (19 MM) DEPTH FOR DRAINAGE CONSISTENCY.
- REFER TO DETAIL OSL 06MD FOR VERTICAL SEAL OF DRYVIT PANEL WEEP SYSTEM.

WEEP TUBE DESIGN PER SPECIFICATION, AS APPLICABLE.

This detail is for general informational purposes, only. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project with respect to any architecture, engineering, and design requirements, including any local building code requirements. If this document is not reviewed and the product is not approved for use by a licensed design professional, the customer agrees that the detail may contain substantive flaws requiring correction, and hereby releases Tremco CPG linc. from any and all liability related to the design and installation of the product. This detail is subject to change without notice. Contact Tremco to ensure you have the most recent version.

## Outsulite™ Panel System



Detail: Horizontal Panel Joint - Drainage Option		
Drawn by:EM	Checked by: CW	Scale: NTS
Revision #: 0	Revised by: NA	Date: 6/27/2024
www.tremcocpg.com		

OSL 12MD

TREMCO

Construction Products Group