

- . MINIMUM 3 5/8" X 1 5/8" X 18 GAUGE STEEL STUDS AT 16" O.C.
- MINIMUM 1/2" EXTERIOR GRADE GYPSUM SHEATHING, MEETING ASTM C 1396 (FORMERLY ASTM C 79) OR MINIMUM 1/2" DENS-GLASS GOLD, USG SECUROCK, OR NATIONAL GYPSUM e2XP SHEATHING, MEETING ASTM C 1177 FASTENED WITH MINIMUM NO. 6 X 1 1/4" SELF TAPPING SCREWS SPACED 6" O.C.
- DRYVIT STANDARD PLUS REINFORCING MESH (6.0 OZ/SQ YD) EMBEDDED IN DRYVIT BACKSTOP® NT™ OR BACKSTOP® NTX™
- 4. DRYVIT PRIMUS® OR GENESIS® ADHESIVE APPLIED IN VERTICAL NOTCHED TROWEL CONFIGURATION TO BACK OF EPS BOARD
- MINIMUM 1" THICK EXPANDED POLYSTYRENE (EPS) INSULATION BOARD MEETING FBC SECTION 2612
- 6. DRYVIT GENESIS BASE COAT
- 7. DRYVIT PANZER® 20 REINFORCING MESH EMBEDDED IN DRYVIT BASE COAT
- DRYVIT STANDARD REINFORCING MESH (4.3 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT

Drawn by: KAB

- DRYVIT FINISH
- 10. FOR FULL NOTICE OF ACCEPTANCE CLICK HERE: NOA 22-0914.14

The architecture, engineering, and design of the project using the Dryvit and Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Dryvit and Tremco to ensure you have the most recent version.

Outsulation® Plus MD System™

www.tremcocpg.com

Scale: NTS



Detail: Outsulation Plus MD System Over 1/2" Gypsum, DensGlass Gold, Securock or e2XP (30 feet or less)

Checked by: KK

Date: 4/2023

NOA 22-0914.14

File Name:

