



Missile Impact Rating: Large & Small
Design Pressure: ±75 psf

1. MINIMUM 3 5/8" X 18 GAUGE STEEL STUDS AT 16" O.C.
2. MINIMUM 1/2" EXTERIOR GRADE GYPSUM SHEATHING MEETING ASTM C 1396 (FORMERLY ASTM C 79) OR MINIMUM 1/2" DENS-GLASS GOLD, USG SECUROCK, OR NATIONAL GYPSUM e2XP SHEATHING MEETING ASTM C 1177 FASTENED WITH NO. 8 X 1 5/8" WAFER HEAD SCREWS SPACED AT 6" O.C.
3. DRYVIT STANDARD PLUS REINFORCING MESH EMBEDDED IN DRYVIT PRIMUS®, GENESIS®, OR GENESIS® DM BASE COAT
4. DRYVIT PRIMUS, GENESIS, OR GENESIS DM ADHESIVE APPLIED IN VERTICAL NOTCHED TROWEL CONFIGURATION TO BACK OF EPS BOARD
5. MINIMUM 1" THICK EXPANDED POLYSTYRENE (EPS) INSULATION BOARD MEETING FBC SECTION 2612
6. DRYVIT PRIMUS, GENESIS, OR GENESIS DM BASE COAT
7. DRYVIT PANZER® 20 REINFORCING MESH (20.5 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT
8. DRYVIT STANDARD REINFORCING MESH (4.3 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT
9. DRYVIT FINISH
10. FOR FULL NOTICE OF ACCEPTANCE CLICK HERE: [NOA 17-0807.14](#)

The architecture, engineering, and design of the project using the Dryvit products is the responsibility of the project's design professional. All systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit specifically disclaims any liability for the use of this detail and for the architecture, design, engineering or workmanship of any project. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. Use of a functionally equivalent detail does not violate Dryvit's warranty. This detail is subject to change without notice. Contact Dryvit to ensure you have the most recent version.

©Dryvit Systems, Inc. | Issued: 11/2017

