

- . MINIMUM 3 5/8" X 18 GAUGE STEEL STUDS AT 16" O.C.
- MINIMUM 5/8" ASTM C 1177 SHEATHING FASTENED WITH MINIMUM NO. 6 X 1 1/4" SELF DRILLING SCREWS SPACED 6" O.C.
- SELF DRILLING SCREWS SPACED 6" O.C.

  3. DRYVIT BACKSTOP® NT OR BACKSTOP® NTX™
- 4. DRYVIT GENESIS® ADHESIVE APPLIED IN VERTICAL NOTCHED TROWEL CONFIGURATION TO BACK OF EPS BOARD
- MINIMUM 1" THICK EXTRUDED POLYSTYRENE (XPS) INSULATION BOARD MEETING FBC SECTION 2612
- 6. WIND-LOCK® WIND-DEVIL 2 FASTENERS- 4 PER 2'-0" X 4'-0" BOARD
- 7. DRYVIT GENESIS BASE COAT
- 8. DRYVIT PANZER® 20 REINFORCING MESH (20.5 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT
- 9. DRYVIT STANDARD REINFORCING MESH (4.3 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT
- DRYVIT FINISH
- 11. PANZER 20 MESH IS NOT REQUIRED ON WALL AREAS THAT ARE GREATER THAN 30 FEET ABOVE GRADE. ONE LAYER OF STANDARD OR STANDARD PLUS (OUTSULATION X) REINFORCING MESH IS REQUIRED ABOVE 30 FEET UNLESS SPECIFIED OTHERWISE BY THE DESIGN PROFESSIONAL.
- 12. FOR FULL NOTICE OF ACCEPTANCE CLICK HERE: NOA 22-0914.10

Drawn by: KAB

The architecture, engineering, and design of the project using the Dryvit and Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Dryvit and Tremco to ensure you have the most recent version.

## Outsulation® X System™



Detail: Outsulation X System Over 5/8" ASTM C 1177 Sheathing

Checked by: KK

,

Scale: NTS Date: 4/2023

NOA 22-0914.10

File Name:



www.tremcocpg.com