



MISSILE IMPACT RATING: LARGE & SMALL	
DESIGN PRESSURE	
6" O.C. SCREWS	±135 PSF
4" O.C. SCREWS	±155 PSF

1. MINIMUM 6" X 18 GAUGE STEEL STUDS AT 16" O.C.
2. MINIMUM 5/8" NATIONAL GYPSUM e²XP SHEATHING FASTENED WITH MINIMUM NO. 6 X 1 1/4" SELF DRILLING SCREWS SPACED IN ACCORDANCE WITH TABLE FOR APPLICABLE DESIGN PRESSURE
3. DRYVIT PANZER® 20 REINFORCING MESH (20.5 OZ/SQ YD) EMBEDDED IN DRYVIT PRIMUS®, GENESIS®, OR GENESIS® DM BASE COAT
4. DRYVIT BACKSTOP® NT™ OR BACKSTOP® NTX™
5. DRYVIT PRIMUS, GENESIS, OR GENESIS DM ADHESIVE APPLIED IN VERTICAL NOTCHED TROWEL CONFIGURATION TO BACK OF EPS BOARD
6. MINIMUM 1" THICK EXPANDED POLYSTYRENE (EPS) INSULATION BOARD MEETING FBC SECTION 2612
7. DRYVIT PRIMUS, GENESIS, OR GENESIS DM BASE COAT
8. DRYVIT STANDARD REINFORCING MESH (4.3 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT
9. DRYVIT FINISH or DRYVIT NEWBRICK®
10. FOR FULL NOTICE OF ACCEPTANCE CLICK HERE: [NOA 22-0914.17](#)

The architecture, engineering, and design of the project using the Dryvit and Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Dryvit and Tremco to ensure you have the most recent version.

Outsulation® Plus MD System™



Dryvit Technical Support: 800-556-7752

Detail: Outsulation Plus MD System Over 5/8" e2XP (30 feet or less)

Drawn by: KAB

Checked by: KK

Scale: NTS

Date: 4/2023

File Name:

NOA 22-0914.17



Construction Products Group

www.tremcocpg.com