

- MINIMUM 3 5/8" X 18 GAUGE STEEL STUDS AT 16" O.C.
- MINIMUM 5/8" NATIONAL GYPSUM e²XP SHEATHING FASTENED WITH
- NO. 6 X 1 1/4" SELF DRILLING SCREWS SPACED 6" O.C.
- DRYVIT PANZER® 20 REINFORCING MESH (20.5 OZ/SQ YD) EMBEDDED IN DRYVIT PRIMUS®, GENESIS®, OR GENESIS® DM BASE COAT
- DRYVIT PRIMUS, GENESIS, OR GENESIS DM ADHESIVE APPLIED IN VERTICAL NOTCHED TROWEL CONFIGURATION TO BACK OF EPS BOARD
- MINIMUM 1" THICK EXPANDED POLYSTYRENE (EPS) INSULATION BOARD **MEETING**
- FBC SECTION 2612 DRYVIT PRIMUS, GENESIS, OR GENESIS DM BASE COAT
- DRYVIT STANDARD REINFORCING MESH (4.3 OZ/SQ YD) EMBEDDED IN DRYVIT BASE COAT

Drawn by: KAB

- DRYVIT FINISH
- FOR FULL NOTICE OF ACCEPTANCE CLICK HERE: NOA 22-0914.16

The architecture, engineering, and design of the project using the Dryvit and Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Dryvit and Tremco to ensure you have the most recent version.

Outsulation® System™



Detail: Outsulation System Over 5/8" e2XP (30 feet or less) Checked by: KK

Date: 4/2023 www.tremcocpg.com

File Name:

NOA 22-0914.16

