



NOTE:

1. REFER TO PRODUCT DATA SHEETS FOR SPECIFIC APPLICATION METHODS.

2. WALL ASSEMBLY SHALL PROVIDE FOR A MAXIMUM DESIGN DEFLECTION OF $L/360$.

3. OPTIONAL CONTINUOUS INSULATION BOARD SHALL HAVE MINIMUM 1/4" WIDE x 1/8" DEEP GROOVES SPACED 12" ON CENTER. GROOVES SHALL BE ORIENTATED VERTICALLY WHEN INSTALLED. JOINTS SHALL BE 1/8" OR LESS AND CLOSED ON THE EXTERIOR SIDE USING MINIMUM 2 3/8" WIDE FIBERGLASS MESH TAPE.

The architecture, engineering, and design of the project using the Dryvit and Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Dryvit and Tremco to ensure you have the most recent version.

StucCoat One Coat® System



Dryvit Technical Support: 800-556-7752

Detail: Horizontal Flashing & Expansion Joint

Drawn by: KAB

Checked by: BD/CB

Scale: NTS

Date: 4/2023

File Name:

SCOC CI 18



Construction Products Group

www.tremcocpg.com